Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZB148

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FONDELL, BOB			Phone #: (920)988-1923
Mailing Address: PO BOX 181			
City: CLYMAN	State: WI	Zip Code: 53016	
County: Dodge	Co. Permit #:	Notification #: 8261286201	Completed: 12-21-2020

Well Constructor (Business Name): UMLAND, RICHARD L	Lic. #: 89	Facility ID # (Public Wells):	
Address: RICKS WELL & PUMP SERVICE W2721 HWY 33 MAYVILLE WI 53050		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3	

1. Well Location

Town of HUSTISFORD					Fire # (if avail.): N3837
Street Address or Road Name and Number: N3837 HWY E					
Subdivision Name			Lot #		Block #
Latitude / Longitude in Decimal Degree (DD): 43.3328 °N -88.6269 °W					Method Code: GPS008
NE SW or Govt Lot #	Section: 17	Township: 10 N	Range: 16 E		

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	80
6	80	202

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		P		P-HARDPAN	Surface	22
		P	C	P-HARDPAN C-CLAYEY	22	80
		L		L-LIMESTONE/DOLOMITE	80	202

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK P.E. 18.97LBS/FT A-53 G-B WHEATLAND	Surface	81
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
43 ft. below ground surface

10. Pump Test
Pumping level 90 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
SODIUM BENTONITE SLURRY	Surface	80	

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RU	89	01-03-2021
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KS	368	01-03-2021

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		141
Building Drain - Sanitary		43
Sewer - Building Sanitary		51
Ditch or Culvert		59
Septic or Holding, or POWTS Tank		90

Comment:

Created On: 02-02-2021 Updated On: 05-07-2021 Review Status: APPROVED