Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZB149

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHWANDT, EAN			Phone #
Mailing Address: W3589 WILDCAT RD			
City: IRON RIDGE	State: WI	Zip Code: 53035	
County: Dodge	Co. Permit #:	Notification #: 8354111101	Completed: 04-30-2021

Well Constructor (Business Name): UMLAND, RICHARD L	Lic. #: 89	Facility ID # (Public Wells):	
Address: RICKS WELL & PUMP SERVICE W2721 HWY 33 MAYVILLE WI 53050		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of HUBBARD

Fire # (if avail.): W3589

Street Address or Road Name and Number: W3589 WILDCAT RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.3849 °N -88.5756 °W	GPS008

NE NW or Govt Lot #	Section	Township	Range
	34	11 N	16 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	113
6	113	256

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		P		P-HARDPAN	Surface	10
T		C		T-TAN/BROWN C-CLAY	10	22
G		C		G-GRAY C-CLAY	22	113
		L		L-LIMESTONE/DOLOMITE	113	256

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK P.E. 18.97LBS/FT A-53 G-B WHEATLAND STEEL	Surface	114
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
SODIUM BENTONITE SLURRY	Surface	113	

9. Static Water Level
57 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 22 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RU	89	05-18-2021
Drill Rig Operator	Lic or Reg #	Date Signed
KS	368	05-18-2021

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		108	Sewer - Building Sanitary		56
Building Drain - Sanitary		31	Septic or Holding, or POWTS Tank		91

Comment:

Created On: 06-02-2021 Updated On: 11-08-2021 Review Status: APPROVED