Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZB832

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: HARTMAN, JOE	Phone #: (920)410-2300
Mailing Address: N5705 SHAMBEAU LK RD	
City: OGDENSBURG	State: WI — Zip Code: 54962
County: Waupaca	Co. Permit #: — Notification #: 7664647301 — Completed: 07-07-2020
Well Constructor (Business Name): WILLIAM VETTER	Lic. #: 6351 — Facility ID # (Public Wells):
Address: 1036 TOWNSEND RD, WAUPACA WI 54981	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 4

1. Well Location

Town of ST. LAWRENCE	Fire # (if avail.): N5705
Street Address or Road Name and Number: N5705 SHAMBEAU LK RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.4469 °N -89.0207 °W	Method Code: SCR002
SW SW or Govt Lot #	Section: 23 — Township: 23 N — Range: 12 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	76

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	D	S	I	K-BLACK D-DECOMPOSED/WEATHERED S-SAND I-W/SOIL-ORGANIC	Surface	1
T	S	Y	S	T-TAN/BROWN S-SOFT/LOOSE Y-SAND & GRAVEL S-SANDY	1	44
G	H	L	C	G-GRAY H-HARD/FIRM L-LIMESTONE/DOLOMITE C-CLAYEY	44	52
T	A	Y	S	T-TAN/BROWN A-COARSE Y-SAND & GRAVEL S-SANDY	52	76

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL WELDED JOINT IPSCO 18.97 PDS PER FT 6.625X280 A53 6RD	Surface	72
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	SS 15 SLOT JOHNSON	72	76

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	6	2 S

9. Static Water Level
45 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WW	6351	07-21-2020
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
GV	8784	07-21-2020

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 09-02-2020 Updated On: 12-23-2020 Review Status: APPROVED