Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZB835

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: VATER-OLSEN, GEORGE & SUSAN	Phone #: (920)596-3471
Mailing Address: E6529 MICKEJOHN RD	
City: NEW LONDON	State: WI — Zip Code: 54961
County: Waupaca	Co. Permit #: — Notification #: 8119167601 — Completed: 08-20-2020
Well Constructor (Business Name): WILLIAM VETTER	Lic. #: 6351 — Facility ID # (Public Wells):
Address: 1036 TOWNSEND RD WAUPACA WI 54981	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 4

1. Well Location

Town of LITTLE WOLF	Fire # (if avail.): N5062
Street Address or Road Name and Number: N5062 CTY RD B	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.4209 °N -88.8818 °W	Method Code: SCR002
NE SE or Govt Lot #:	Section: 35 — Township: 23 N — Range: 13 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of BARN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	42

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	H	I	T	T-TAN/BROWN H-HARD/FIRM I-SOIL-ORGANIC T-W/TILL	Surface	2
T	H	C	M	T-TAN/BROWN H-HARD/FIRM C-CLAY M-SILTY	2	5
T	N	S	M	T-TAN/BROWN N-FINE S-SAND M-SILTY	5	7
R	H	C	C	R-RED H-HARD/FIRM C-CLAY C-CLAYEY	7	30
R	A	Y	G	R-RED A-COARSE Y-SAND & GRAVEL G-W/GRAVEL/STONES	30	32
T	W	S	S	T-TAN/BROWN W-WATER BEARING S-SAND S-SANDY	32	42

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL WELDED JOINT IPSCO 18.97 PD PER FT 6.625X280 A53 GRB	Surface	39
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	12 SLOT S.S. JOHNSON	39	42

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	6	1 S

9. Static Water Level	11. Well Is
16 ft. below ground surface	18 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 20 ft. below surface	Disinfected ? Yes
Pumping at 16 GP M for 1 Hrs.	Capped ? Yes
Pumping Method ? Airlift	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WV	6351	08-20-2020
Drill Rig Operator	Lic or Reg #	Date Signed
GV	8784	08-20-2020

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Animal Yard - Include Hutches		75
Animal Barn or Barn Pen		75	Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 09-16-2020 Updated On: 01-21-2021 Review Status: APPROVED