

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZB835		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner VATER-OLSEN, GEORGE & SUSAN						Phone # (920)596-3471		1. Well Location				Fire # (if avail.)			
Mailing Address E6529 MICKEJOHN RD						Town of LITTLE WOLF						N5062			
City NEW LONDON						State WI		Zip Code 54961				Street Address or Road Name and Number N5062 CTY RD B			
County Waupaca		Co. Permit #		Notification # 8119167601		Completed 08-20-2020		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) WILLIAM VETTER				Lic. # 6351		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.4209 °N -88.8818 °W				Method Code SCR002	
Address 1036 TOWNSEND RD WAUPACA WI 54981				Well Plan Approval #		NE SE		Section 35		Township 23 N		Range 13 E		2. Well Type New Well	
Hicap Permanent Well #				Common Well #		Specific Capacity 4				of previous unique well # constructed in					
3. Well serves 1 # of BARN				Hicap Well ? No		Reason for replaced or reconstructed well ?									
Private, potable				Hicap Property ? No		Construction Type Drilled									
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Reason for replaced or reconstructed well ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		42		No Rotary - Mud Circulation				No					
6		Surface		42		No Rotary - Air				No					
6		Surface		42		No Rotary - Air & Foam				No					
6		Surface		42		No Drill-Through Casing Hammer				No					
6		Surface		42		No Reverse Rotary				No					
6		Surface		42		Yes Cable-tool Bit 6in. dia...				No					
6		Surface		42		No Dual Rotary				No					
6		Surface		42		No Temp. Outer Casing ___ in. dia				No					
6		Surface		42		No Removed? ___ depth ft. (If NO explain on back side)				No					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology					
6		STEEL WELDED JOINT IPSCO 18.97 PD PER FT 6.625X280 A53 GRB				Surface		39		Geology Codes					
6		12 SLOT S.S. JOHNSON				39		42		Type, Caving/Noncaving, Color, Hardness, etc...					
6		12 SLOT S.S. JOHNSON				39		42		From (ft.)					
6		12 SLOT S.S. JOHNSON				39		42		To (ft.)					
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
BENTONITE				Surface		6		1 S							
T H I T															
T H C M															
T N S M															
R H C C															
R A Y G															
T W S S															

9. Static Water Level

16 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 16 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

WV

6351

08-20-2020

Drill Rig Operator

Lic or Reg #

Date Signed

GV

8784

08-20-2020

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Animal Yard - Include Hutches		75
Animal Barn or Barn Pen		75	Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 09-16-2020

Updated On: 01-21-2021

Review Status: APPROVED