

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZC448		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner JOHNNEK, MIKE						Phone # (715)853-5228		1. Well Location				Fire # (if avail.)							
Mailing Address W5060 NORTHWOOD DR						Town of WESCOTT						5060							
City CECIL						State WI		Zip Code 54166				Street Address or Road Name and Number NORTHWOOD DR							
County Shawano		Co. Permit #		Notification # 7619275501		Completed 05-06-2019		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) YOUNG JR, RAYMOND				Lic. # 455		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.85 °N -88.4975 °W				Method Code GPS008					
Address CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 1 27 N 16 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? SHORT WATER											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		Construction Type Drilled													
3. Well serves 1 # of HOME				Hicap Well ? No															
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		161		No Rotary - Mud Circulation		No		S		S-SAND		Surface		28			
						No Rotary - Air		No		C S		C-CLAY S-SANDY		28		158			
						No Rotary - Air & Foam		No		G		G-GRAVEL/STONES		158		161			
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...		No											
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				24 in. above grade					
6		IPSCO ASTMA53 WELDED				Surface		161		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 65 ft. below surface				Disinfected ? Yes					
										Pumping at 18 GP M for 24 Hrs.				Capped ? Yes					
										Pumping Method ? Test Pump									
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Yes							
												Filled & Sealed Well(s) as needed? Yes PLUMBER							
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												RY				455		05-06-2019	
Drill Rig Operator				Lic or Reg #		Date Signed													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		114	Septic or Holding, or POWTS Tank		55

Comment:

Created On: 06-06-2019

Updated On: 09-25-2019

Review Status: APPROVED