Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZC448

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHNNEK, MIKE	Phone #: (715)853-5228
Mailing Address: W5060 NORTHWOOD DR	
City: CECIL	State: WI — Zip Code: 54166
County: Shawano	Co. Permit #:
Notification #: 7619275501	Completed: 05-06-2019
Well Constructor (Business Name): YOUNG JR, RAYMOND	Lic. #: 455
Facility ID # (Public Wells):	
Address: CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.7	

1. Well Location

Town of WESCOTT	Fire # (if avail.): 5060
Street Address or Road Name and Number: NORTHWOOD DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.85 °N -88.4975 °W	Method Code: GPS008
NW NE or Govt Lot #:	Section: 1 — Township: 27 N — Range: 16 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: SHORT WATER

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	161

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	28
		C	S	C-CLAY S-SANDY	28	158
		G		G-GRAVEL/STONES	158	161

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO ASTMA53 WELDED	Surface	161
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 18 GP M for 24 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

PLUMBER

13. Constructor / Supervisory Driller	Lic #	Date Signed
RY	455	05-06-2019
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		114	Septic or Holding, or POWTS Tank		55

Comment:

Created On: 06-06-2019 Updated On: 09-25-2019 Review Status: APPROVED