

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZC449		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner MUELLER, ROY						Phone # (920)810-2928		1. Well Location				Fire # (if avail.)					
Mailing Address W156 HUCKLEBERRY CT						Town of MENOMINEE						W156					
City GILLETT						State WI		Zip Code 54124				Street Address or Road Name and Number HUCKLEBERRY CT					
County Menominee		Co. Permit #		Notification # 7619275502		Completed 05-08-2019		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) YOUNG JR, RAYMOND				Lic. # 455		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.8944 °N -88.4919 °W				Method Code GPS008			
Address CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 26 24 28 N 16 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? SHORT WATER Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5													
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		100		No Rotary - Mud Circulation		No		S		S-SAND		Surface		35	
						No Rotary - Air		No		C S		C-CLAY S-SANDY		35		95	
						No Rotary - Air & Foam		No		W S		W-WATER BEARING S-SAND		95		100	
						No Drill-Through Casing Hammer Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				24 in. above grade			
6		WHEATLAND ASTMA53 WELDED				Surface		97		10. Pump Test Pumping level 70 ft. below surface Pumping at 15 GP M for 24 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		6 SLOT SS STEEL				97		100									
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? No PLUMBER Filled & Sealed Well(s) as needed? Yes PLUMBER					
13. Constructor / Supervisory Driller						Lic #		Date Signed									
RY						455		05-08-2019									
Drill Rig Operator						Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 06-06-2019

Updated On: 07-25-2019

Review Status: APPROVED