Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZC449

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	MUELLER, ROY
Phone #	(920)810-2928
Mailing Address	W156 HUCKLEBERRY CT
City	GILLETT
State	WI
Zip Code	54124
County	Menominee
Co. Permit #	
Notification #	7619275502
Completed	05-08-2019
Well Constructor (Business Name)	YOUNG JR, RAYMOND
Lic. #	455
Facility ID # (Public Wells)	
Address	CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.5

1. Well Location

Town of MENOMINEE	Fire # (if avail.) W156
Street Address or Road Name and Number	HUCKLEBERRY CT
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	44.8944 °N -88.4919 °W
Method Code	GPS008

SW	NE	Section	Township	Range
or Govt Lot #	26	24	28 N	16 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

SHORT WATER

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	100

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	35
		C	S	C-CLAY S-SANDY	35	95
	W	S		W-WATER BEARING S-SAND	95	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND ASTMA53 WELDED	Surface	97
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	6 SLOT SS STEEL	97	100

7. Grout or Other Sealing Material

Method

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 15 GP M for 24 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

PLUMBER

Filled & Sealed Well(s) as needed? Yes

PLUMBER

13. Constructor / Supervisory Driller	Lic #	Date Signed
RY	455	05-08-2019
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 06-06-2019 Updated On: 07-25-2019 Review Status: APPROVED