

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZC451		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner HERZOG, JON						Phone # (920)604-0091		1. Well Location				Fire # (if avail.)		
Mailing Address 5441 DEGANTOWN RD						Town of OCONTO FALLS						5441		
City GILLETT						State WI		Zip Code 54124				Street Address or Road Name and Number DEGANTOWN RD		
County Oconto		Co. Permit #		Notification # 7642189201		Completed 05-16-2019		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) YOUNG JR, RAYMOND				Lic. # 455		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.8703 °N -88.2283 °W				Method Code GPS008		
Address CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587				Well Plan Approval #		SE SE		Section 30		Township 28 N		Range 19 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		2. Well Type New Well								
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? Construction Type Drilled						
						Hicap Property ? No								
						Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		38		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)				
S		S-SAND						Surface		20				
C S		C-CLAY S-SANDY						20		35				
W S		W-WATER BEARING S-SAND						35		38				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes				
6		WHEATLAND WELDED ASTMA53				Surface		35						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
5		6 SLOT S.S. SCREEN				35		38						
7. Grout or Other Sealing Material Method														
9. Static Water Level 10 ft. below ground surface														
10. Pump Test Pumping level 30 ft. below surface Pumping at 8 GP M for 24 Hrs. Pumping Method ? Other														
12. Notified Owner of need to fill & seal ? No NEW Filled & Sealed Well(s) as needed? No NEW														
13. Constructor / Supervisory Driller						Lic #		Date Signed						
RY						455		05-16-2019						
Drill Rig Operator						Lic or Reg #		Date Signed						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 06-06-2019

Updated On: 07-25-2019

Review Status: APPROVED