Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZC451

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HERZOG, JON			Phone #: (920)604-0091
Mailing Address: 5441 DEGANTOWN RD			
City: GILLETT	State: WI	Zip Code: 54124	
County: Oconto	Co. Permit #:	Notification #: 7642189201	Completed: 05-16-2019

Well Constructor (Business Name): YOUNG JR, RAYMOND	Lic. #: 455	Facility ID # (Public Wells):	
Address: CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of OCONTO FALLS

Fire # (if avail.): 5441

Street Address or Road Name and Number: DEGANTOWN RD

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 44.8703 °N -88.2283 °W
Method Code: GPS008

SE or Govt Lot #	SE	Section: 30	Township: 28 N	Range: 19 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	38

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	20
		C	S	C-CLAY S-SANDY	20	35
	W	S		W-WATER BEARING S-SAND	35	38

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND WELDED ASTMA53	Surface	35
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	6 SLOT S.S. SCREEN	35	38

7. Grout or Other Sealing Material
Method

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 8 GP M for 24 Hrs.
Pumping Method ? Other

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
NEW

Filled & Sealed Well(s) as needed? No
NEW

13. Constructor / Supervisory Driller	Lic #	Date Signed
RY	455	05-16-2019
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 06-06-2019 Updated On: 07-25-2019 Review Status: APPROVED