

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZC901		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner RICKSTER, MARY Phone # (414)426-6656						1. Well Location				Fire # (if avail.)	
Mailing Address 8106 S FOREST HLS CIR						Town of BERENT				209563	
City FRANKLIN State WI Zip Code 53132						Street Address or Road Name and Number S CO RD Y					
County Marathon		Co. Permit #		Notification # 7264803901		Completed 07-18-2018		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) DREWS, EDWARD J				Lic. # 327		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.7675 °N -89.3911 °W		Method Code SCR002	
Address DREWS WELL DRLG R15289 RINGLE AVE RINGLE WI 54471				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 3 26 N 9 E		2. Well Type Replacement			
Hicap Permanent Well #		Common Well #		Specific Capacity 6		Reason for replaced or reconstructed well ? BASEMENT DRIVE POINT/REAL ESTATE SALE					
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
6		Surface		48		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...	
								V Y		V-NON-CAVING Y-SAND & GRAVEL	
								C G		C-CLAY G-W/GRAVEL/STONES	
								Q Y		Q-CAVING Y-SAND & GRAVEL	
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is	
6		JYUNDAI A53B 18.97 WELDED				Surface		45		18 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes Disinfected ? Yes Capped ? Yes	
5		STAINLESS 25 SLOT K-PAC				45		48			
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
CETCO #8				Surface				0.5 S			
9. Static Water Level											
29.5 ft. below ground surface											
10. Pump Test											
Pumping level 32 ft. below surface											
Pumping at 15 GP M for 1 Hrs.											
Pumping Method ? Test Pump											
12. Notified Owner of need to fill & seal ? Yes											
Filled & Sealed Well(s) as needed? Yes											
EXISTING WELL TO BE ABANDONED AFTER NEW WELL IS CONNECTED											
13. Constructor / Supervisory Driller						Lic #		Date Signed			
FJD						327		07-28-2018			
Drill Rig Operator						Lic or Reg #		Date Signed			
MK								07-28-2018			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		38

Comment:

Created On: 08-22-2018

Updated On: 10-12-2018

Review Status: APPROVED