Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZC901

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RICKSTER, MARY	Phone #: (414)426-6656
Mailing Address: 8106 S FOREST HLS CIR	
City: FRANKLIN	State: WI — Zip Code: 53132
County: Marathon	Co. Permit #: — Notification #: 7264803901 — Completed: 07-18-2018
Well Constructor (Business Name): DREWS, EDWARD J	Lic. #: 327 — Facility ID # (Public Wells):
Address: DREWS WELL DRLG R15289 RINGLE AVE RINGLE WI 54471	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #:	Specific Capacity: 6

1. Well Location

Town of BERENT	Fire # (if avail.): 209563
Street Address or Road Name and Number: S CO RD Y	
Subdivision Name: — Lot #: — Block #:	
Latitude / Longitude in Decimal Degree (DD): 44.7675 °N -89.3911 °W	Method Code: SCR002
NE NE or Govt Lot #: — Section: 3 — Township: 26 N — Range: 9 E	

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: BASEMENT DRIVE POINT/REAL ESTATE SALE

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	48

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	V	Y		V-NON-CAVING Y-SAND & GRAVEL	Surface	5
		C	G	C-CLAY G-W/GRAVEL/STONES	5	24
	Q	Y		Q-CAVING Y-SAND & GRAVEL	24	48

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	JYUNDAI A53B 18.97 WELDED	Surface	45
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	STAINLESS 25 SLOT K-PAC	45	48

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CETCO #8	Surface		0.5 S

9. Static Water Level

29.5 ft. below ground surface

10. Pump Test

Pumping level 32 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

EXISTING WELL TO BE ABANDONED AFTER NEW WELL IS CONNECTED

13. Constructor / Supervisory Driller	Lic #	Date Signed
FJD	327	07-28-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MK		07-28-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		38

Comment:

Created On: 08-22-2018 Updated On: 10-12-2018 Review Status: APPROVED