

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZD087		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SCHROEDER, MICHAEL						Phone # (715)347-5030		1. Well Location				Fire # (if avail.)			
Mailing Address 215 PLEASANT STREET						Village of SCANDINAVIA						215			
City SCANDINAVIA						State WI		Zip Code 54977				Street Address or Road Name and Number PLEASANT STREET			
County Waupaca		Co. Permit #		Notification # 7445704401		Completed 11-15-2018		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) SOIK R J PLBG & HTG INC				Lic. # 2868		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.4574 °N -89.1451 °W				Method Code GPS008	
Address PO BOX 265 1512 WATER ST STEVENS POINT WI 54481-0265				Well Plan Approval #		NE NE		Section 22		Township 23 N		Range 11 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type Replacement						of previous unique well #		constructed in	
3. Well serves 1 # of HOME						Hicap Well ? No		Reason for replaced or reconstructed well ? FAILED WELL							
Private, potable						Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ? No		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		70		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T	V	Z		T-TAN/BROWN V-NON-CAVING Z-CLAY & GRAVEL				Surface		16					
R	V	C		R-RED V-NON-CAVING C-CLAY				16		47					
R	V	Z		R-RED V-NON-CAVING Z-CLAY & GRAVEL				47		65					
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL				65		70					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL A53B 18.97 WHEATLAND WELD				Surface		70							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		12 SLOT STAINLESS STEEL TELESCOPING				66		70							
9. Static Water Level															
31 ft. below ground surface															
10. Pump Test															
Pumping level 41 ft. below surface															
Pumping at 17 GP M for 1 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
19 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
GRANULAR BENTONITE		Surface		66		1 S									
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
WS				Lic # 480				Date Signed 11-15-2018							
Drill Rig Operator				Lic or Reg #				Date Signed							
LM				7416				11-15-2018							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Landfill	=	1199

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Landfill Variance	12/19/2018	PROPERTY WITHIN 1200 FEET OF LANDFILL

Created On: 12-18-2018

Updated On: 05-08-2020

Review Status: APPROVED