Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZD087

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHROEDER, MICHAEL	Phone #: (715)347-5030
Mailing Address: 215 PLEASANT STREET	
City: SCANDINAVIA	State: WI Zip Code: 54977
County: Waupaca	Co. Permit #:
Notification #: 7445704401	Completed: 11-15-2018
Well Constructor (Business Name): SOIK R J PLBG & HTG INC	Lic. #: 2868
Facility ID # (Public Wells):	
Address: PO BOX 265 1512 WATER ST STEVENS POINT WI 54481-0265	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.7	

1. Well Location

Village of SCANDINAVIA	Fire # (if avail.): 215
Street Address or Road Name and Number: PLEASANT STREET	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 44.4574 °N -89.1451 °W	Method Code: GPS008
NE NE or Govt Lot #:	Section: 22 Township: 23 N Range: 11 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: FAILED WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	70

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	Z		T-TAN/BROWN V-NON-CAVING Z-CLAY & GRAVEL	Surface	16
R	V	C		R-RED V-NON-CAVING C-CLAY	16	47
R	V	Z		R-RED V-NON-CAVING Z-CLAY & GRAVEL	47	65
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	65	70

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL A53B 18.97 WHEATLAND WELD	Surface	70
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	12 SLOT STAINLESS STEEL TELESCOPING	66	70

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	66	1 S

9. Static Water Level

31 ft. below ground surface

10. Pump Test

Pumping level 41 ft. below surface

Pumping at 17 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

19 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
WS	480	11-15-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
LM	7416	11-15-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Landfill	=	1199

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Landfill Variance	12/19/2018	PROPERTY WITHIN 1200 FEET OF LANDFILL

Created On: 12-18-2018 Updated On: 10-15-2026 Review Status: APPROVED