

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZD152		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner DOHNER, JAMES						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address E10861 TERRYTOWN RD						Town of BARABOO						E10861			
City BARABOO						State WI		Zip Code 53913				Street Address or Road Name and Number E10861 TERRYTOWN RD			
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #	
Sauk				7403348301		12-12-2018									
Well Constructor (Business Name) STUHR, RANDY C				Lic. # 58		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.4849 °N -89.7819 °W				Method Code GPS008	
Address CTW CORPORATION 624 AMY DR HOLMEN WI 54636				Well Plan Approval #		SE SE		Section 28		Township 12 N		Range 6 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #				Common Well #		Specific Capacity 15				2. Well Type New Well					
										of previous unique well # constructed in					
										Reason for replaced or reconstructed well ?					
										Construction Type Drilled					
3. Well serves 1 # of HOME						Hicap Well ? No									
Private, potable						Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ? Yes									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		185											
						No Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S				S-SAND				Surface		59					
X				X-SAND & CLAY				59		124					
S				S-SAND				124		174					
A S G				A-COARSE S-SAND G-W/GRAVEL/STONES				174		185					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL ASTM A53 18.97 GRADE B WELDED JOINT WHEATLAND USA				Surface		182							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
5		STAINLESS STEEL #25 SLOT COOK SCREENS				182		185							
7. Grout or Other Sealing Material Method															
9. Static Water Level 90 ft. below ground surface															
10. Pump Test Pumping level 91 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ? Other															
11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
DWS				38		12-30-2018									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Sewer - Building Sanitary		108
Other Contamination Sources		66	Septic or Holding, or POWTS Tank		102

Comment:

Created On: 02-19-2019

Updated On: 03-06-2019

Review Status: APPROVED