Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZD152

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: DOHNER, JAMES	Phone #
Mailing Address: E10861 TERRYTOWN RD	
City: BARABOO	State: WI — Zip Code: 53913
County: Sauk	Co. Permit #: — Notification #: 7403348301 — Completed: 12-12-2018
Well Constructor (Business Name): STUHR, RANDY C	Lic. #: 58 — Facility ID # (Public Wells):
Address: CTW CORPORATION 624 AMY DR HOLMEN WI 54636	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 15

1. Well Location

Town of BARABOO			Fire # (if avail.): E10861
Street Address or Road Name and Number: E10861 TERRYTOWN RD			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 43.4849 °N -89.7819 °W			Method Code: GPS008
SE SE or Govt Lot #:	Section: 28	Township: 12 N	Range: 6 E

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? Yes

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	185

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	S			S-SAND	Surface	59
	X			X-SAND & CLAY	59	124
	S			S-SAND	124	174
A	S	G		A-COARSE S-SAND G-W/GRAVEL/STONES	174	185

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL ASTM A53 18.97 GRADE B WELDED JOINT WHEATLAND USA	Surface	182
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS STEEL #25 SLOT COOK SCREENS	182	185

9. Static Water Level
90 ft. below ground surface

10. Pump Test
Pumping level 91 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ? Other

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DWS	38	12-30-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Sewer - Building Sanitary		108
Other Contamination Sources		66	Septic or Holding, or POWTS Tank		102

Comment:

Created On: 02-19-2019 Updated On: 03-06-2019 Review Status: APPROVED