Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZD964

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LARSON, TRUDY	Phone #
Mailing Address: 722 CO RD G	
City: NEKOOSA	State: WI — Zip Code: 54457
County: Wood	Co. Permit #: — Notification #: 7438110101 — Completed: 11-02-2018
Well Constructor (Business Name): ROTH WELL DRILLLING	Lic. #: 5857 — Facility ID # (Public Wells):
Address: 618 HWY 73S, NEKOOSA WI 54457	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #:	Specific Capacity: 5.9

1. Well Location

Town of PORT EDWARDS

Fire # (if avail.):

Street Address or Road Name and Number: 722 CO RD G

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 44.2716 °N -89.962 °W — Method Code: SCR002

NW SW or Govt Lot #: — Section: 30 — Township: 21 N — Range: 5 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: OLD WELL FAILING

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? Yes

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	50

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
A	S	S	A-COARSE S-SAND S-SANDY	Surface	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	A53B .280 WHEATLAND WELDED	Surface	47
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	TELE JOHNSON 12 SLOT SS	47	50

9. Static Water Level

11.6 ft. below ground surface

10. Pump Test

Pumping level 15 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KR	4495	11-23-2018
Drill Rig Operator	Lic or Reg #	Date Signed
MG	3740	11-23-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Sewer - Building Sanitary		30
			Septic or Holding, or POWTS Tank		45

Comment:

Created On: 12-17-2018 Updated On: 05-05-2020 Review Status: APPROVED