

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZE449		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner SCHULTZ, DON						Phone # (715)224-2243		1. Well Location				Fire # (if avail.)		
Mailing Address N10057 SUNSET POINT RD						Town of BRADLEY						N10057		
City TOMAHAWK						State WI		Zip Code 54487				Street Address or Road Name and Number SUNSET POINT RD		
County Lincoln		Co. Permit #		Notification # 7667582601		Completed 06-04-2019		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) KOMAREK SR, RONALD A				Lic. # 610		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.4787 °N -89.7776 °W			Method Code GPS008	
Address KOMAREK WELL DRILLING N1690 ST HWY 13 OGEMA WI 54459				Well Plan Approval #		NE NE		Section 31		Township 35 N		Range 6 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		2. Well Type Replacement								
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in						
						Hicap Property ? No		Reason for replaced or reconstructed well ? SLOW POINT						
						Hicap Potable ? Yes		Construction Type Drilled						
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		247		No Rotary - Mud Circulation				No				
						No Rotary - Air				No				
						No Rotary - Air & Foam				No				
						No Drill-Through Casing Hammer								
						No Reverse Rotary								
						No Cable-tool Bit ___ in. dia...				No				
						No Dual Rotary				No				
						No Temp. Outer Casing ___ in. dia								
						No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
S				S-SAND				Surface		24				
C M				C-CLAY M-SILTY				24		31				
E G				E-CLEAN G-GRAVEL/STONES				31		36				
G U				G-GRAVEL/STONES U-MUDDY OR MURKY				36		46				
G Q				G-GRAY Q-GRANITE				46		247				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6.625		280 ASTM A53B 18.97# WELD JT WHEATLAND				Surface		46						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
GRANULAR BENTONITE				Surface										
9. Static Water Level														
11 ft. below ground surface														
10. Pump Test														
Pumping level 215 ft. below surface														
Pumping at 25 GP M for 1 Hrs.														
Pumping Method ? Test Pump														
11. Well Is														
16 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ? Yes														
Filled & Sealed Well(s) as needed? Yes														
13. Constructor / Supervisory Driller				Lic #		Date Signed								
RK				6961		06-07-2019								
Drill Rig Operator				Lic or Reg #		Date Signed								

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		61	Septic or Holding, or POWTS Tank		48

Comment:

Created On: 06-25-2019

Updated On: 06-25-2019

Review Status: APPROVED