Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZE451

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WALDBERGER, ALAN			Phone #
Mailing Address: N4464 CO RD K			
City: MERRILL	State: WI	Zip Code: 54452	
County: Lincoln	Co. Permit #:	Notification #: 7668404601	Completed: 06-10-2019

Well Constructor (Business Name): KOMAREK SR, RONALD A	Lic. #: 610	Facility ID # (Public Wells):	
Address: KOMAREK WELL DRILLING N1690 ST HWY 13 OGEMA WI 54459		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? Yes

1. Well Location
Town of MERRILL

Fire # (if avail.): N4464

Street Address or Road Name and Number: CO RD K

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 45.2779 °N -89.6616 °W			Method Code: GPS008
NW NE or Govt Lot #:	Section: 7	Township: 32 N	Range: 7 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
STATE OWNS OTHER WELL

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	102

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
P	P-HARDPAN	Surface	44
G	G-GRAVEL/STONES	44	78
S	S-SAND	78	102

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	280 ASTM A53B 18.97 # WELD JT IPSCO	Surface	98
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
3	12 SLOT SS JOHNSON	98	102

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level
56 ft. below ground surface

10. Pump Test
Pumping level 75 ft. below surface
Pumping at 8 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? No
STATE OWNS

13. Constructor / Supervisory Driller	Lic #	Date Signed
RK	6961	06-10-2019
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		53	Septic or Holding, or POWTS Tank		71

Comment: 1/27/2020 - CALLED OWNER ABOUT F&S OLD WELL. OWNER EXPLAINED THAT WELL IS NEAR A PROPOSED ROAD AND THAT THE STATE OR COUNTY NOW OWNS THE LAND THE WELL IS ON.

Created On: 06-26-2019 Updated On: 01-28-2020 Review Status: APPROVED