

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZE452		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner NERISON, RON						Phone # (920)788-9496		1. Well Location				Fire # (if avail.)			
Mailing Address 1201 HIETPAS ST						Town of GEORGETOWN						W10705			
City LITTLE CHUTE						State WI		Zip Code 54140				Street Address or Road Name and Number POPLAR LN			
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #	
Price				7633681802		06-10-2019									
Well Constructor (Business Name) KOMAREK SR, RONALD A				Lic. # 610		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.5951 °N -90.6078 °W				Method Code GPS008	
Address KOMAREK WELL DRILLING N1690 ST HWY 13 OGEMA WI 54459				Well Plan Approval #				NE NW Section Township Range or Govt Lot # 22 36 N 2 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ?					
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4				Construction Type Drilled					
3. Well serves 1 # of HOME				Hicap Well ? No											
Private, potable				Hicap Property ? No											
Heat Exchange ____ # of drillholes				Hicap Potable ? Yes											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		134											
						<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ____ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ____ in. dia <u>No</u> Removed? ____ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
P				P-HARDPAN				Surface		49					
C				C-CLAY				49		133					
Y				Y-SAND & GRAVEL				133		134					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6.625		280 ASTM A53B 18.97# WELD JT WHEATLAND				Surface		134							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRAN BENTONITE				Surface											
9. Static Water Level															
44 ft. below ground surface															
10. Pump Test															
Pumping level 59 ft. below surface															
Pumping at 6 GP M for 1 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
15 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
RK				6961		06-11-2019									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 06-25-2019

Updated On: 06-25-2019

Review Status: APPROVED