

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZF377		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner DOESCHER, SCOTT					Phone #			1. Well Location Fire # (if avail.) Town of MARATHON Street Address or Road Name and Number 14623 WHIPPOORWILL				
Mailing Address 9010 WINDEMERE PL												
City WESTON			State WI		Zip Code 54476							
County Marathon		Co. Permit #		Notification # 7633354501		Completed 05-09-2019		Subdivision Name			Lot # Block #	
Well Constructor (Business Name)				Lic. # 9013		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code	
HORNUNG JR, JAMES								44.9306 °N -89.7286 °W			GPS008	
Address HORNUNG WELL DRLG LLC N952 CTY HWY W MERRILL WI 54452				Well Plan Approval #		SE SE Section Township Range						
				Approval Date (mm-dd-yyyy)		or Govt Lot # 1		28 N 6 E				
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled						
3. Well serves 1 # of SHOP Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		
8		Surface		40		No Rotary - Mud Circulation		No		C C C-CLAY Surface 6		
6		40		100		No Rotary - Air		No		K D Q K-BLACK D-DECOMPOSED/WEATHERED Q-GRANITE 6 32		
						Yes Rotary - Air & Foam		No		K H Q K-BLACK H-HARD/FIRM Q-GRANITE 32 100		
						No Drill-Through Casing Hammer						
						No Reverse Rotary						
						No Cable-tool Bit ___ in. dia...		No				
						No Dual Rotary		No				
						Yes Temp. Outer Casing 10in. dia						
						Yes Removed? 10depth ft. (If NO explain on back side)						
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 18 ft. below ground surface		
6		FEMCO 530 6.625 280 WALL WELDED USA				Surface		40		11. Well Is 18 in. above grade		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes Disinfected ? Yes Capped ? Yes		
7. Grout or Other Sealing Material												
Method DISPLACEMENT												
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement						
NEAT GROUT		Surface		40		9 S						
12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No												
13. Constructor / Supervisory Driller						Lic #		Date Signed				
JH						9013		05-09-2019				
Drill Rig Operator						Lic or Reg #		Date Signed				

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-25-2019

Updated On: 09-26-2019

Review Status: APPROVED