Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZF379

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: FISHER			Phone #
Mailing Address: 1110 S 50TH AVE APT 107			
City: WAUSAU	State: WI	Zip Code: 54401	
County: Marathon	Co. Permit #:	Notification #: 7641289001	Completed: 05-15-2019

1. Well Location
Town of STETTIN
Fire # (if avail.)
Street Address or Road Name and Number: N 80TH AVE
Subdivision Name | Lot # | Block #

Well Constructor (Business Name): HORNUNG JR, JAMES	Lic. #: 9013	Facility ID # (Public Wells)	
Address: HORNUNG WELL DRLG LLC N952 CTY HWY W, MERRILL WI 54452		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.1	

Latitude / Longitude in Decimal Degree (DD): 45.0053 °N -89.7382 °W
Method Code: GPS008

SE	SW	Section	Township	Range
or Govt Lot #		12	29 N	6 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of NEW HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	58

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	30
X	X-SAND & CLAY	30	55
G	G-GRAVEL/STONES	55	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	FEMCO 530 6.625 .280 WALL WELDED USA	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
21 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUND

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface		1 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	9013	05-15-2019
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 06-25-2019 Updated On: 06-25-2019 Review Status: APPROVED