

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZF379		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner FISHER					Phone #			1. Well Location				Fire # (if avail.)			
Mailing Address 1110 S 50TH AVE APT 107								Town of STETTIN							
City WAUSAU					State WI		Zip Code 54401		Street Address or Road Name and Number				N 80TH AVE		
County Marathon		Co. Permit #		Notification # 7641289001		Completed 05-15-2019		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) HORNUNG JR, JAMES					Lic. # 9013		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.0053 °N -89.7382 °W				Method Code GPS008		
Address HORNUNG WELL DRLG LLC N952 CTY HWY W MERRILL WI 54452					Well Plan Approval #		SE SW		Section 12		Township 29 N		Range 6 E		
					Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #			Common Well #		Specific Capacity 1.1		Reason for replaced or reconstructed well ?								
3. Well serves 1 # of NEW HOME					Hicap Well ? No		Construction Type Drilled								
Private, potable					Hicap Property ? No										
Heat Exchange ___ # of drillholes					Hicap Potable ? No										
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock						
6		Surface		58		No Rotary - Mud Circulation			No						
						No Rotary - Air			No						
						No Rotary - Air & Foam			No						
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...			No						
						No Dual Rotary			No						
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)						
Y			Y-SAND & GRAVEL			Surface			30						
X			X-SAND & CLAY			30			55						
G			G-GRAVEL/STONES			55			58						
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		FEMCO 530 6.625 .280 WALL WELDED USA				Surface		40							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUND															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
BENTONITE				Surface				1 S							
9. Static Water Level															
21 ft. below ground surface															
10. Pump Test															
Pumping level 40 ft. below surface															
Pumping at 20 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
JH				9013				05-15-2019							
Drill Rig Operator				Lic or Reg #				Date Signed							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-25-2019

Updated On: 06-25-2019

Review Status: APPROVED