Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZH695

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FENSKE, JAMES			Phone #
Mailing Address: 1736 MONTICELLO			
City: JACKSON	State: WI	Zip Code: 53037	
County: Washington	Co. Permit #:	Notification #: 8097717001	Completed: 08-05-2020

1. Well Location
Town of JACKSON
Fire # (if avail.)
Street Address or Road Name and Number: 1736 MONTICELLO DR
Subdivision Name | Lot # | Block #

Well Constructor (Business Name): LIEBAU LAUN INC	Lic. #: 527	Facility ID # (Public Wells)	
Address: 1200 W LIEBAU RD 124N MEQUON WI 53092-3334		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.4	

Latitude / Longitude in Decimal Degree (DD): 43.3114 °N -88.1238 °W
Method Code: GPS008

SE or Govt Lot #	SE	Section: 21	Township: 10 N	Range: 20 E

2. Well Type Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?: WATER QUALITY
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	150
6	150	225

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	C-CLAY G-W/GRAVEL/STONES	Surface	25
		L		L-LIMESTONE/DOLOMITE	25	225

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53-B EXL TUBE 6.625 X .280 PC WELDERS	Surface	150
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
36 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 10 GP M for 4 Hrs.
Pumping Method ? Test Pump

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	150	23 S

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
AL	23	08-12-2020
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 09-16-2020 Updated On: 01-27-2021 Review Status: APPROVED