Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZJ448

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	WENINGER, DOUG
Phone #	
Mailing Address	W7814 COUNTRY AVE
City	HOLMEN
State	WI
Zip Code	54636

County	Co. Permit #	Notification #	Completed
La Crosse	2020002	7890640901	01-15-2020

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LYSAKER, ERIC	6735	

Address: LYSAKER WELL DRLG & SERV LLC
N5452 EAGLE CIRCLE LN W
ONALASKA WI 54650

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.4

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Fire # (if avail.): W7814

Town of HOLLAND

Street Address or Road Name and Number: W7814 COUNTRY AVE

Subdivision Name	Lot #	Block #
4TH ADD. COUNTRY EST.	14	13

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.9771 °N -91.2959 °W	SCR002

NW SE or Govt Lot #	Section	Township	Range
	2	17 N	8 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD SCREEN PLUGGED

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	129

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	129

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK PE STEEL .237 WALL 10.79# ASTM A53B WHEATLAND WELDED	Surface	123
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	STAINLESS STEEL 15 SLOT CONT.	123	129

7. Grout or Other Sealing Material

Method

9. Static Water Level
75 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 10 GP M for 24 Hrs.
Pumping Method ? Test Pump

11. Well Is
17 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EL	6735	02-04-2020
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Sewer - Building Sanitary		40
Building Drain - Sanitary		16	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 08-03-2020 Updated On: 10-05-2020 Review Status: APPROVED