

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZJ448		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner WENINGER, DOUG						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address W7814 COUNTRY AVE						Town of HOLLAND						W7814					
City HOLMEN						State WI		Zip Code 54636				Street Address or Road Name and Number W7814 COUNTRY AVE					
County La Crosse		Co. Permit # 2020002		Notification # 7890640901		Completed 01-15-2020		Subdivision Name 4TH ADD. COUNTRY EST.				Lot # 14 Block # 13					
Well Constructor (Business Name) LYSAKER, ERIC				Lic. # 6735		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9771 °N -91.2959 °W				Method Code SCR002			
Address LYSAKER WELL DRLG & SERV LLC N5452 EAGLE CIRCLE LN W ONALASKA WI 54650				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 2 17 N 8 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD SCREEN PLUGGED									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		Construction Type Drilled											
3. Well serves 1 # of HOME				Hicap Well ? No													
Private, potable				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
4		Surface		129		No Rotary - Mud Circulation		No		Y		Y-SAND & GRAVEL		Surface		129	
						No Rotary - Air		No									
						No Rotary - Air & Foam		No									
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		75 ft. below ground surface				17 in. above grade			
4		NEW BLACK PE STEEL .237 WALL 10.79# ASTM A53B WHEATLAND WELDED				Surface		123		10. Pump Test				Developed ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 100 ft. below surface				Disinfected ? Yes			
3.5		STAINLESS STEEL 15 SLOT CONT.				123		129		Pumping at 10 GP M for 24 Hrs.				Capped ? Yes			
										Pumping Method ? Test Pump							
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Yes					
												Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller						Lic #		Date Signed									
EL						6735		02-04-2020									
Drill Rig Operator						Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Sewer - Building Sanitary		40
Building Drain - Sanitary		16	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 08-03-2020

Updated On: 10-05-2020

Review Status: APPROVED