Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZJ449

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	BROOKS, NATE
Phone #	
Mailing Address	1167 KANE ST
City	LA CROSSE
State	WI
Zip Code	54603

County	Co. Permit #	Notification #	Completed
La Crosse	2020018	7905712001	02-18-2020

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LYSAKER, ERIC	6735	

Address: LYSAKER WELL DRLG & SERV LLC
N5452 EAGLE CIRCLE LN W
ONALASKA WI 54650

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.5

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of CAMPBELL

Fire # (if avail.) 1613

Street Address or Road Name and Number
1613 CAROLINE ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.8462	°N	-91.2627	°W	SCR002

NE SW or Govt Lot #	Section	Township	Range
	19	16 N	7 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD POINT PLUGGED

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	65

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK PE STEEL .237 WALL 10.79# ASTM A53B WHEATLAND WELDED	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	STAINLESS STEEL 15 SLOT CONT	62	65

7. Grout or Other Sealing Material

Method

9. Static Water Level
9 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 10 GP M for 4 Hrs.
Pumping Method ? Test Pump

11. Well Is
48 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EL	6735	02-27-2020
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? Yes

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		80	Building Drain - Sanitary		16
			Sewer - Building Sanitary		20

Comment:

Created On: 08-12-2020 Updated On: 11-24-2020 Review Status: APPROVED