Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZJ450

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner	HANSON, SUSAN
Phone #	
Mailing Address	W8060 FORREST DR
City	ONALASKA
State	WI
Zip Code	54650

County	Co. Permit #	Notification #	Completed
La Crosse	2020020	7910231801	02-25-2020

1. Well Location

Fire # (if avail.)
W8060

Town of ONALASKA

Street Address or Road Name and Number: FORREST DR

Subdivision Name	Lot #	Block #
PRAIRIE PARK	9	2

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LYSAKER, ERIC	6735	

Address: LYSAKER WELL DRLG & SERV LLC
N5452 EAGLE CIRCLE LN W
ONALASKA WI 54650

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.2

Latitude / Longitude in Decimal Degree (DD): 43.9496 °N -91.3082 °W

Method Code: SCR002

SW	NW	Section	Township	Range
or Govt Lot #		14	17 N	8 W

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD SCREEN PLUGGED

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	105

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK PE STEEL .237 WALL 10.79# ASTM A53B WHEATLAND WELDED	Surface	102
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	STAINLESS STEEL 15 SLOT CONT	102	105

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 10 GP M for 24 Hrs.
Pumping Method ? Test Pump

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes
NOT YET

13. Constructor / Supervisory Driller	Lic #	Date Signed
EL	6735	02-27-2020
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Sewer - Building Sanitary		30
Building Drain - Sanitary		16	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 08-12-2020 Updated On: 10-31-2023 Review Status: APPROVED