

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZJ451		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner LINBERG, KYLE						Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address W24453 STATE RD 54/93						Town of TREMPPEALEAU				W24453				
City TREMPPEALEAU						State WI		Zip Code 54661				Street Address or Road Name and Number W24453 STATE RD 54/93		
County Trempealeau		Co. Permit # 26206056		Notification # 7906929801		Completed 02-22-2020		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) LYSAKER, ERIC				Lic. # 6735		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0696 °N -91.4402 °W			Method Code SCR002	
Address LYSAKER WELL DRLG & SERV LLC N5452 EAGLE CIRCLE LN W ONALASKA WI 54650				Well Plan Approval #		NW NE		Section 3		Township 18 N		Range 9 W		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		2. Well Type Replacement of previous unique well # constructed in								
						Reason for replaced or reconstructed well ? OLD PUMP STUCK IN WELL								
3. Well serves 1 # of HOME Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
4		Surface		87										
						No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ____ in. dia... No No Dual Rotary No No Temp. Outer Casing ____ in. dia No Removed? ____ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
Y				Y-SAND & GRAVEL				Surface		87				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 45 ft. below ground surface				
4		NEW BLACK PE STEEL .237 WALL 10.79# ASTM A53B WHEATLAND WELD				Surface		81		11. Well Is 18 in. above grade				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes Disinfected ? Yes Capped ? Yes				
3.5		STAINLESS STEEL 12 SLOT CONT.				81		87		Pumping level 70 ft. below surface Pumping at 16 GP M for 24 Hrs. Pumping Method ? Test Pump				
7. Grout or Other Sealing Material Method														
12. Notified Owner of need to fill & seal ? Yes Filled & Sealed Well(s) as needed? Yes NOT YET														
13. Constructor / Supervisory Driller								Lic #		Date Signed				
EL								6735		02-27-2020				
Drill Rig Operator								Lic or Reg #		Date Signed				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Sewer - Building Sanitary		37
Building Drain - Sanitary		14	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 08-12-2020

Updated On: 10-31-2023

Review Status: APPROVED