Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZJ831

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: LYON, BONNIE	Phone #: (715)479-9767
Mailing Address: 1695 WILDERNESS TRL	
City: EAGLE RIVER	State: WI — Zip Code: 54521
County: Vilas	Co. Permit #:
Notification #: 8140901801	Completed: 09-29-2020
Well Constructor (Business Name): WRANIK THOMAS F WELL DRILLING INC	Lic. #: 6031
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 620 W PINE ST BOX 1266 EAGLE RIVER WI 54521	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.4	

1. Well Location

Town of LINCOLN			Fire # (if avail.)
Street Address or Road Name and Number: APPLE VALLEY LN			
Subdivision Name: APPLE VALLEY	Lot #: 5	Block #:	
Latitude / Longitude in Decimal Degree (DD): 45.8692 °N -89.2511 °W			Method Code: SCR002
SE NW or Govt Lot #:	Section: 16	Township: 39 N	Range: 10 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	41

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	N	S		N-FINE S-SAND	Surface	35
	A	Y		A-COARSE Y-SAND & GRAVEL	35	41

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B WELDED WHEATLAND SEC 40X20 18.97LB	Surface	38
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	TEL JOHNSON SS #7	38	41

7. Grout or Other Sealing Material
Method

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 12 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW	70	09-29-2020
Drill Rig Operator	Lic or Reg #	Date Signed
PN	7304	09-29-2020

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 10-22-2020 Updated On: 11-10-2020 Review Status: APPROVED