Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZJ832

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	CAPSAY, ALAN
Phone #	(715)617-1102
Mailing Address	2035 SWAINSONS RUN
City	NAPLES
State	FL
Zip Code	34105

County	Co. Permit #	Notification #	Completed
Vilas		8109906501	10-01-2020

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
WRANIK THOMAS F WELL DRILLING INC	6031	

Address: 620 W PINE ST BOX 1266, EAGLE RIVER WI 54521

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.7

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

1. Well Location

Town of WASHINGTON

Fire # (if avail.) 1833

Street Address or Road Name and Number: SCATTERING RICE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.936 °N	-89.183 °W			SCR002

	SW	NE	Section	Township	Range
or Govt Lot #	2		24	40 N	10 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

LOCATION

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	37

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	F	S-SAND F-W/FILL	Surface	16
		S	G	S-SAND G-W/GRAVEL/STONES	16	30
		Y		Y-SAND & GRAVEL	30	37

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B WELDED WHEATLAND 18.97 LB SEC 40X20	Surface	34
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	TEL JOHNSON SS #10	34	37

7. Grout or Other Sealing Material

Method

9. Static Water Level

16 ft. below ground surface

10. Pump Test

Pumping level 25 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW	70	10-01-2020
Drill Rig Operator	Lic or Reg #	Date Signed
PN	7304	10-01-2020

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 10-22-2020 Updated On: 11-10-2020 Review Status: APPROVED