

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZJ833		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner DECOSOLA, RON						Phone # (630)333-5182		1. Well Location				Fire # (if avail.)					
Mailing Address 7019 BONKOWSKI RD						Town of THREE LAKES						7019					
City THREE LAKES						State WI		Zip Code 54562				Street Address or Road Name and Number BONKOWSKI RD					
County Oneida		Co. Permit #		Notification # 8042152701		Completed 10-02-2020		Subdivision Name GOV'T LOT 6 & 7				Lot # 3		Block #			
Well Constructor (Business Name) WRANIK THOMAS F WELL DRILLING INC				Lic. # 6031		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.8016 °N -89.1177 °W				Method Code SCR002			
Address 620 W PINE ST BOX 1266 EAGLE RIVER WI 54521				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 6 4 38 N 11 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 1.8													
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		40		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>Yes</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				Y Y-SAND & GRAVEL S S-SAND Y Y-SAND & GRAVEL		Surface 22 35 40		22 35 40			
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		19 ft. below ground surface		12 in. above grade					
6		A53B WELDED WHEATLAND 18.97LB SEC 40X20				Surface		37		10. Pump Test Pumping level 30 ft. below surface Pumping at 20 GP M for 2 Hrs. Pumping Method ? Test Pump		Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		TEL JOHNSON SS #10				37		40									
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No					
13. Constructor / Supervisory Driller								Lic #		Date Signed							
TW								70		10-02-2020							
Drill Rig Operator								Lic or Reg #		Date Signed							
PN								7304		10-02-2020							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 10-22-2020

Updated On: 04-07-2021

Review Status: APPROVED