Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZJ833

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: DECOSOLA, RON	Phone #: (630)333-5182
Mailing Address: 7019 BONKOWSKI RD	
City: THREE LAKES	State: WI — Zip Code: 54562
County: Oneida	Co. Permit #:
Notification #: 8042152701	Completed: 10-02-2020
Well Constructor (Business Name): WRANIK THOMAS F WELL DRILLING INC	Lic. #: 6031
Facility ID # (Public Wells):	
Address: 620 W PINE ST BOX 1266 EAGLE RIVER WI 54521	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.8	

1. Well Location

Town of THREE LAKES	Fire # (if avail.): 7019
Street Address or Road Name and Number: BONKOWSKI RD	
Subdivision Name: GOV'T LOT 6 & 7	Lot #: 3 — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.8016 °N -89.1177 °W	Method Code: SCR002

NE	SE	Section	Township	Range
or Govt Lot # 6	4	38 N	11 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	40

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		Y-SAND & GRAVEL	Surface	22
		S		S-SAND	22	35
		Y		Y-SAND & GRAVEL	35	40

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B WELDED WHEATLAND 18.97LB SEC 40X20	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	TEL JOHNSON SS #10	37	40

7. Grout or Other Sealing Material
Method

9. Static Water Level
19 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW	70	10-02-2020
Drill Rig Operator	Lic or Reg #	Date Signed
PN	7304	10-02-2020

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 10-22-2020 Updated On: 04-07-2021 Review Status: APPROVED