

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZJ920		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner US SHELTER					Phone #		1. Well Location				Fire # (if avail.)												
Mailing Address 40115 94TH PL																							
City GENOA CITY					State WI		Zip Code 53128		Town of RANDALL														
Street Address or Road Name and Number					40115 94TH PL																		
County Kenosha		Co. Permit #		Notification # 8140541902		Completed 10-08-2020		Subdivision Name			Lot #		Block #										
Well Constructor (Business Name)				Lic. # 6740		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code									
GEHRING LANCE WELL DRILLING INC										42.5353 °N -88.2976 °W				GPS008									
Address 8820 KAROW RD TWIN LAKES WI 53181				Well Plan Approval #		NE NW		Section 19		Township 1 N		Range 19 E											
				Approval Date (mm-dd-yyyy)		or Govt Lot #																	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled																	
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No		Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
9		Surface		68		<u>Yes</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>Yes</u> Temp. Outer Casing 14in. dia <u>Yes</u> Removed? 2depth ft. (If NO explain on back side)						G		G-GRAVEL/STONES		Surface		53					
												N G		N-FINE G-GRAVEL/STONES		53		68					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		23 ft. below ground surface				14 in. above grade									
5		200LB PVC 1120 SDR 21F480 SOLVENT WELD				Surface		64		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 55 ft. below surface				Disinfected ? Yes									
5		STAINLESS STEEL				64		68		Pumping at 10 GP M for 24 Hrs.				Capped ? Yes									
										Pumping Method ? Airlift													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No									
Method		PRESSURE PUMP																					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No															
CETCO		Surface		64		7 S																	
13. Constructor / Supervisory Driller														Lic #		Date Signed							
LG														6994		10-08-2020							
Drill Rig Operator														Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 11-02-2020

Updated On: 11-10-2020

Review Status: APPROVED