

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZK217		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner LAMBERT, DAN						Phone # (715)216-8053		1. Well Location				Fire # (if avail.)					
Mailing Address PO BOX 74						Village of WHITE LAKE											
City WHITE LAKE						State WI		Zip Code 54491									
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #			
Langlade				8035094602		06-04-2020											
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code					
T & T WELL DRILLING				6571				45.1538 °N -88.786 °W				GPS008					
Address PO BOX 22 LAKEWOOD WI 54138				Well Plan Approval #		SE NE		Section		Township		Range					
						or Govt Lot #		19		31 N		14 E					
Approval Date (mm-dd-yyyy)						2. Well Type New Well											
Hicap Permanent Well #				Common Well #		Specific Capacity		of previous unique well # constructed in									
						0.8		Reason for replaced or reconstructed well ?									
3. Well serves 1 # of HOUSE				Hicap Well ? No		Construction Type Drilled											
Private, potable				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		50		Yes Rotary - Mud Circulation		No		Y C		Y-SAND & GRAVEL C-CLAYEY		Surface		45	
6		50		80		No Rotary - Air		No		Y		Y-SAND & GRAVEL		45		80	
						No Rotary - Air & Foam		No									
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is			
6		ASTM A-53 GR B WHEATLAND WELDED 18.97 PER FT				Surface		77		30 ft. below ground surface				15 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes			
5		STAINLESS #15				77		80		Pumping level 66 ft. below surface				Disinfected ? Yes			
										Pumping at 30 GP M for 2 Hrs.				Capped ? Yes			
										Pumping Method ? Airlift							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method MOUNDED																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
SAND-BENTONITE				Surface		50		S									
												13. Constructor / Supervisory Driller					
												Lic #		Date Signed			
												6220		10-18-2020			
												Drill Rig Operator		Lic or Reg #		Date Signed	
												8359		10-29-2020			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Septic or Holding, or POWTS Tank	>	25

Comment:

THIS PROJECT WAS NOT FINISHED TILL LATER BECAUSE OF BUILDING DELAYS CAUSED FROM COVID VIRUS

Created On: 11-23-2020

Updated On: 05-04-2021

Review Status: APPROVED