

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZL321		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner STEVENSON, BRIAN						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N2529 WEGNER RD						Town of CORNING									
City MERRILL						State WI		Zip Code 54452							
County Lincoln		Co. Permit #		Notification # 8135656201		Completed 10-09-2020		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) HORNUNG WELL DRLG LLC				Lic. # 6781		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.2082 °N -89.9206 °W				Method Code GPS008	
Address N925 CTY HWY W MERRILL WI 54452				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 36 32 N 4 E				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1									
3. Well serves 1 # of NEW HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		72											
						No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
Y		Y-SAND & GRAVEL				Surface		69							
R C		R-RED C-CLAY				69		70							
K Q		K-BLACK Q-GRANITE				70		72							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		FEMCO 530 6.625 .280 WALL WELDED USA 18.9#				Surface		70							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
BENTONITE		Surface				1 S									
9. Static Water Level															
4 ft. below ground surface															
10. Pump Test															
Pumping level 65 ft. below surface Pumping at 5 GP M for 1 Hrs. Pumping Method ? Airlift															
11. Well Is															
18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
JH				9013		10-09-2020									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 10-05-2020

Updated On: 02-16-2021

Review Status: APPROVED