

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZL322		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner OHLMANN JR, FRED					Phone #		1. Well Location Fire # (if avail.) Town of PINE RIVER W347 Street Address or Road Name and Number W347 STATE RD 64				
Mailing Address W347 STATE RD 64											
City MERRILL			State WI	Zip Code 54452		Subdivision Name Lot # Block #					
County Lincoln	Co. Permit #	Notification # 8140563801		Completed 10-10-2020							
Well Constructor (Business Name) HORNUNG WELL DRLG LLC			Lic. # 9013	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.1479 °N -89.4387 °W			Method Code GPS008		
Address N925 CTY HWY W MERRILL WI 54452			Well Plan Approval #		NE NW	Section 25	Township 31 N	Range 8 E		2. Well Type Replacement of previous unique well # constructed in 1950 Reason for replaced or reconstructed well ? LOW HOLE TOO SMALL Construction Type Drilled	
			Approval Date (mm-dd-yyyy)		or Govt Lot #						
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1							
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock				
6	Surface	100	No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
		K	C				K-COBBLER/BOULDERS C-CLAYEY	Surface		43	
K	H	Q					K-BLACK H-HARD/FIRM Q-GRANITE	43		100	
6. Casing, Liner, Screen											
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)						
6	FEMCO 530 6.625 .280 WALL WELDED USA 18.9#			Surface	43						
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)						
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement							
BENTONITE		Surface		1 S							
9. Static Water Level 15 ft. below ground surface											
10. Pump Test Pumping level 90 ft. below surface Pumping at 5 GP M for 1 Hrs. Pumping Method ? Airlift											
11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes											
12. Notified Owner of need to fill & seal ? Yes Filled & Sealed Well(s) as needed? Yes STILL IN USE											
13. Constructor / Supervisory Driller				Lic #		Date Signed					
JH				9013		10-16-2020					
Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 11-02-2020

Updated On: 10-30-2023

Review Status: APPROVED