

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZL327		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner GUNTNER, TOWN OF, (WHITT, JOANIE)						Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address 1660 KNAPT RD						Town of GUENTHER								
City MOSINEE						State WI		Zip Code 54455				Street Address or Road Name and Number 157835 CO C		
County Marathon		Co. Permit #		Notification # 8153351801		Completed 09-30-2020		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) HORNUNG WELL DRLG LLC				Lic. # 9013		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.7139 °N -89.5825 °W			Method Code GPS008	
Address N925 CTY HWY W MERRILL WI 54452				Well Plan Approval #		NE NW		Section 29		Township 26 N		Range 8 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type New Well				of previous unique well # constructed in				
3. Well serves 1 # of SHOP Non-community Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Reason for replaced or reconstructed well ?								
						Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
8		Surface		40		No Rotary - Mud Circulation				No				
6		40		200		No Rotary - Air				No				
						Yes Rotary - Air & Foam				Yes				
						No Drill-Through Casing Hammer								
						No Reverse Rotary								
						No Cable-tool Bit ___ in. dia...				No				
						No Dual Rotary				No				
						Yes Temp. Outer Casing 10in. dia								
						Yes Removed? 10depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
R		C				R-RED C-CLAY		Surface		6				
D		Q				D-DECOMPOSED/WEATHERED Q-GRANITE		6		15				
R		H		Q		R-RED H-HARD/FIRM Q-GRANITE		15		200				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		FEMCO 530 60621 .280 WALL WELDED USA 18.9				Surface		40						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method GROUT DISPLACEMENT (PLUG)														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
NEAT GROUT				Surface		40		8 S						
9. Static Water Level														
16 ft. below ground surface														
10. Pump Test														
Pumping level 180 ft. below surface														
Pumping at 4 GP M for 12 Hrs.														
Pumping Method ? Test Pump														
11. Well Is														
18 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ? No														
Filled & Sealed Well(s) as needed? No														
13. Constructor / Supervisory Driller														
Lic #				Date Signed										
JH				9013				09-30-2020						
Drill Rig Operator				Lic or Reg #				Date Signed						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment: BOX 4A - NOT IN YET

Rehab Type	Rehab Date	Result Text
Hydrofracture	10/19/2020	DRY HOLE BEFORE HYDROFRACTED

Created On: 11-02-2020

Updated On: 04-28-2021

Review Status: APPROVED