

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZL401		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WOODS & MEADOWS						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N4335 POTTER RD								Town of KNAPP				N4319			
City WARRENS						State WI		Zip Code 54666				Street Address or Road Name and Number N4319 POTTER RD			
County Jackson		Co. Permit #		Notification # 8125429701		Completed 09-02-2020		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) RUSH WELL DRILLING LLC				Lic. # 6462		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.2274 °N -90.5219 °W				Method Code GPS008	
Address N7570 ODEEN ROAD BLACK RIVER FALLS WI 54615-5818				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 8 20 N 1 W		2. Well Type Replacement				of previous unique well # constructed in			
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		Reason for replaced or reconstructed well ? OLD WELL BAD LOCATION				Construction Type Drilled					
3. Well serves 1 # of FARM				Hicap Well ? No		Private, potable				Hicap Property ? No					
Heat Exchange ___ # of drillholes				Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology						
10 Surface 33			No Rotary - Mud Circulation No			No Rotary - Air No			Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)						
6 33 80			No Rotary - Air & Foam No			No Drill-Through Casing Hammer			Q S K Q-CAVING S-SAND K-W/BROKEN ROCK Surface 13						
			No Reverse Rotary			Yes Cable-tool Bit 10in. dia... Yes			T H N T-TAN/BROWN H-HARD/FIRM N-SANDSTONE 13 80						
			No Dual Rotary No			Yes Temp. Outer Casing 10in. dia									
			No Removed? 13depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is			
6		STEEL #18.97/FT ASTM A53B MARIUCHI WELDED				Surface		33		31 ft. below ground surface		20 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes			
										Pumping level 48 ft. below surface		Disinfected ? Yes			
										Pumping at 10 GP M for 4 Hrs.		Capped ? Yes			
										Pumping Method ? Test Pump					
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Yes					
NEAT CEMENT GROUT				Surface		33		14 S		Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller															
Lic #				Date Signed				13. Constructor / Supervisory Driller							
JR				5837				09-04-2020							
Drill Rig Operator				Lic or Reg #				Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		56	Sewer - Building Sanitary		23
			Septic or Holding, or POWTS Tank		42

Comment:

Created On: 10-22-2020

Updated On: 04-08-2021

Review Status: APPROVED