

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZL416		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner PETERSON, CAROL						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 30051 HWY 12						Town of OAKDALE						30051			
City TOMAH						State WI		Zip Code 54660				Street Address or Road Name and Number 30051 HWY 12			
County Monroe		Co. Permit #		Notification # 8110610301		Completed 08-17-2020		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) RUSH WELL DRILLING LLC				Lic. # 6462		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9633 °N -90.3917 °W				Method Code GPS008	
Address N7570 ODEEN ROAD BLACK RIVER FALLS WI 54615-5818				Well Plan Approval #				SW NW		Section 9		Township 17 N		Range 1 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 1				2. Well Type New Well					
Hicap Property ? No				Hicap Potable ? No				of previous unique well #				constructed in			
Heat Exchange ___ # of drillholes				Hicap Well ? No				Reason for replaced or reconstructed well ?							
3. Well serves 1 # of HOME				Private, potable				Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
10		Surface		30		No Rotary - Mud Circulation				No					
6		30		60		No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						Yes Cable-tool Bit 10in. dia...				Yes					
						No Dual Rotary				No					
						Yes Temp. Outer Casing 10in. dia									
						Yes Removed? 12depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)				To (ft.)			
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND				Surface				12			
	H	N	C	H-HARD/FIRM N-SANDSTONE C-CLAYEY				12				42			
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE				42				60			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL #18.97/FT ASTM A53B LEAVITT WELDED				Surface		30							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method TREMIE/PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT				Surface		30		15 S							
9. Static Water Level															
18 ft. below ground surface															
10. Pump Test															
Pumping level 26 ft. below surface															
Pumping at 8 GP M for 3 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
26 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
JR				Lic # 5837		Date Signed 08-18-2020									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Sewer - Building Sanitary		30
			Septic or Holding, or POWTS Tank		32

Comment:

Created On: 10-22-2020

Updated On: 04-09-2021

Review Status: APPROVED