Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZL416

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: PETERSON, CAROL			Phone #
Mailing Address: 30051 HWY 12			
City: TOMAH	State: WI	Zip Code: 54660	
County: Monroe	Co. Permit #:	Notification #: 8110610301	Completed: 08-17-2020

Well Constructor (Business Name): RUSH WELL DRILLING LLC	Lic. #: 6462	Facility ID # (Public Wells):	
Address: N7570 ODEEN ROAD BLACK RIVER FALLS WI 54615-5818		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1	

1. Well Location

Town of OAKDALE					Fire # (if avail.): 30051
Street Address or Road Name and Number: 30051 HWY 12					
Subdivision Name			Lot #		Block #
Latitude / Longitude in Decimal Degree (DD): 43.9633 °N -90.3917 °W					Method Code: GPS008
SW	NW	Section: 9	Township: 17 N		Range: 1 E
or Govt Lot #					

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	30
6	30	60

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	Yes
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 12depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	Surface	12
	H	N	C	H-HARD/FIRM N-SANDSTONE C-CLAYEY	12	42
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	42	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL #18.97/FT ASTM A53B LEAVITT WELDED	Surface	30
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 26 ft. below surface
Pumping at 8 GP M for 3 Hrs.
Pumping Method ? Test Pump

11. Well Is
26 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE/PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	30	15 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JR	5837	08-18-2020
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50

Type	Qualifier	Distance
Sewer - Building Sanitary		30
Septic or Holding, or POWTS Tank		32

Comment:

Created On: 10-22-2020 Updated On: 04-09-2021 Review Status: APPROVED