

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZL418		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner OTT, MIKE						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address W11184 HILTS RD						Town of ALBION						W11184	
City BLACK RIVER FALLS						State WI		Zip Code 54615				Street Address or Road Name and Number W11184 HILTS RD	
County Jackson		Co. Permit #		Notification # 8093905901		Completed 07-28-2020		Subdivision Name HILTS			Lot # Block #		
Well Constructor (Business Name) RUSH WELL DRILLING LLC				Lic. # 6462		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 44.2858 °N -90.8716 °W			Method Code GPS008	
Address N7570 ODEEN ROAD BLACK RIVER FALLS WI 54615-5818				Well Plan Approval #			SW NE Section Township Range or Govt Lot # 21 21 N 4 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled				
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.8									
3. Well serves 1 # of SHED Private, non-potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
10		Surface		40		<u>No</u> Rotary - Mud Circulation			<u>No</u>				
6		40		90		<u>No</u> Rotary - Air			<u>No</u>				
						<u>No</u> Rotary - Air & Foam			<u>No</u>				
						<u>No</u> Drill-Through Casing Hammer							
						<u>No</u> Reverse Rotary							
						<u>Yes</u> Cable-tool Bit 10in. dia...			<u>Yes</u>				
						<u>No</u> Dual Rotary			<u>No</u>				
						<u>Yes</u> Temp. Outer Casing 10in. dia							
						<u>Yes</u> Removed? 23depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)		To (ft.)					
T		C	T-TAN/BROWN C-CLAY			Surface		18					
T	Q	S	T-TAN/BROWN Q-CAVING S-SAND			18		23					
T	H	N	T-TAN/BROWN H-HARD/FIRM N-SANDSTONE			23		90					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		STEEL #18.97/FT ASTM A53B LEAVITT WELDED				Surface		40					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
NEAT CEMENT				Surface		40		17 S					
9. Static Water Level													
56 ft. below ground surface													
10. Pump Test													
Pumping level 68 ft. below surface Pumping at 10 GP M for 2 Hrs. Pumping Method ? Test Pump													
11. Well Is													
16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller													
JR				Lic # 5837		Date Signed 07-28-2020							
Drill Rig Operator				Lic or Reg #		Date Signed							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: NO SEWER INSTALLED

Created On: 10-22-2020

Updated On: 04-08-2021

Review Status: APPROVED