Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZL418

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: OTT, MIKE			Phone #
Mailing Address: W11184 HILTS RD			
City: BLACK RIVER FALLS	State: WI	Zip Code: 54615	
County: Jackson	Co. Permit #:	Notification #: 8093905901	Completed: 07-28-2020

Well Constructor (Business Name): RUSH WELL DRILLING LLC	Lic. #: 6462	Facility ID # (Public Wells):	
Address: N7570 ODEEN ROAD BLACK RIVER FALLS WI 54615-5818		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.8	

3. Well serves 1 # of SHED
Private, non-potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of ALBION			Fire # (if avail.): W11184
Street Address or Road Name and Number: W11184 HILTS RD			
Subdivision Name: HILTS	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 44.2858 °N -90.8716 °W			Method Code: GPS008

SW	NE	Section	Township	Range
or Govt Lot #		21	21 N	4 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	40
6	40	90

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	Yes
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 23depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		C		T-TAN/BROWN C-CLAY	Surface	18
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	18	23
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	23	90

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL #18.97/FT ASTM A53B LEAVITT WELDED	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	40	17 S

9. Static Water Level
56 ft. below ground surface

10. Pump Test
Pumping level 68 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JR	5837	07-28-2020
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: NO SEWER INSTALLED

Created On: 10-22-2020 Updated On: 04-08-2021 Review Status: APPROVED