Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZL419

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BUSH, GREG			Phone #
Mailing Address: W11761 SPRING CREEK RD			
City: BLACK RIVER FALLS	State: WI	Zip Code: 54615	
County: Jackson	Co. Permit #:	Notification #: 8104175901	Completed: 08-10-2020

Well Constructor (Business Name): RUSH WELL DRILLING LLC	Lic. #: 6462	Facility ID # (Public Wells):	
Address: N7570 ODEEN ROAD BLACK RIVER FALLS WI 54615-5818		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.9	

1. Well Location

Town of ALBION			Fire # (if avail.): W11761
Street Address or Road Name and Number: W11761 SPRING CREEK RD			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 44.2604 °N -90.8969 °W			Method Code: GPS008
NE NW or Govt Lot #:	Section: 32	Township: 21 N	Range: 4 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of SHED
Private, non-potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	110

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	Surface	18
G		U		G-GRAY U-MUD OR MUCK	18	73
	Q	S	C	Q-CAVING S-SAND C-CLAYEY	73	91
I	H	N		I-WHITE H-HARD/FIRM N-SANDSTONE	91	110

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL #18.97/FT ASTM A53B LEAVITT WELDED	Surface	91
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		5 S

9. Static Water Level
38 ft. below ground surface

10. Pump Test
Pumping level 49 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JR	5837	08-15-2020
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50

Type	Qualifier	Distance
Sewer - Building Sanitary	>	20
Septic or Holding, or POWTS Tank	>	25

Comment: SEWER NOT INSTALLED AT TIME OF WELL

Created On: 10-22-2020 Updated On: 04-08-2021 Review Status: APPROVED