

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZL430		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner MCCARVILLE, MIKE Phone # (813)309-8654						1. Well Location				Fire # (if avail.)	
Mailing Address 3721 HALF MOON CIRCLE						Town of JACKSON				3721	
City DANBURY State WI Zip Code 54830						Street Address or Road Name and Number HALF MOON CIRCLE					
County Burnett		Co. Permit #		Notification # 8807660501		Completed 05-24-2022		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) JENNEMANS HARDWARE HANK INC				Lic. # 704		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.9485 °N -92.174 °W		Method Code SCR002	
Address PO BOX 10 SIREN WI 54872-0010				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 13 40 N 15 W		2. Well Type Replacement of previous unique well # constructed in			
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ? PLUGGED SANDPOINT					
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Driven Point					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
2		Surface		62		No Rotary - Mud Circulation			No		
						No Rotary - Air			No		
						No Rotary - Air & Foam			No		
						No Drill-Through Casing Hammer					
						No Reverse Rotary					
						No Cable-tool Bit ___ in. dia...			No		
						No Dual Rotary			No		
6. Casing, Liner, Screen				No Temp. Outer Casing ___ in. dia							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
2		ASTM53, WHEATLAND USA, THREADED				Surface		59			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
2		80 GA, STAINLESS STEEL				59		62			
7. Grout or Other Sealing Material Method											
8. Geology											
9. Static Water Level						11. Well Is					
44 ft. below ground surface						12 in. above grade					
10. Pump Test						Developed ? Yes					
Pumping level ___ ft. below surface						Disinfected ? Yes					
Pumping at ___ GP for ___ Hrs.						Capped ? Yes					
Pumping Method ?											
12. Notified Owner of need to fill & seal ? Yes											
Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller						Lic #		Date Signed			
MS						6630		07-19-2022			
Drill Rig Operator						Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		59	Sewer - Building Sanitary		25
			Septic or Holding, or POWTS Tank		38

Comment:

Created On: 04-14-2023

Updated On: 05-15-2023

Review Status: APPROVED