Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZM454

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	MEDVERZ, STEPHEN
Phone #	
Mailing Address	167546 CO RD G
City	WAUSAU
State	WI
Zip Code	54403
County	Marathon
Co. Permit #	
Notification #	8493487901
Completed	08-10-2021
Well Constructor (Business Name)	HORNUNG JR, JAMES
Lic. #	9013
Facility ID # (Public Wells)	
Address	HORNUNG WELL DRLG LLC, N925 CTY HWY W MERRILL WI 54452
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0

1. Well Location

Town of	HEWITT
Fire # (if avail.)	
Street Address or Road Name and Number	166575 TRAPPE RD
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	45.0822 °N -89.4673 °W
Method Code	GPS008
NW SW or Govt Lot #	
Section	18
Township	30 N
Range	9 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	200

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Z		Z-CLAY & GRAVEL	Surface	35
G		C		G-GRAY C-CLAY	35	47
E	D	Q		E-GREEN D-DECOMPOSED/WEATHERED Q-GRANITE	47	51
K		Q		K-BLACK Q-GRANITE	51	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	FEMCO 530 6.625 .280 WALL WELDED USA 18.9#	Surface	51
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

22 ft. below ground surface

10. Pump Test

Pumping level 190 ft. below surface

Pumping at 20 GP H for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface		2 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	9013	08-10-2021
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 09-10-2021 Updated On: 10-15-2026 Review Status: APPROVED