

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZM750		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner SCHULTZ, BRANDON				Phone # (719)291-3808		1. Well Location				Fire # (if avail.) 897			
Mailing Address 375 WAGON TONGUE RD						Town of AURORA							
City BAILEY				State CO		Zip Code 80421							
County Florence		Co. Permit #		Notification # 8935452601		Completed 10-25-2022		Subdivision Name		Lot # Block #			
Well Constructor (Business Name) KLEIMAN, ERIK P				Lic. # 6720		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.8478 °N -88.1028 °W		Method Code GPS008			
Address KLEIMAN PUMP & WELL DRLG PO BOX 704 IRON MOUNTAIN MI 49801-0704				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 22 39 N 19 E		2. Well Type New Well					
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled							
Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
6	Surface	43	No Rotary - Mud Circulation No Yes Rotary - Air Yes No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						G Z G-GRAVEL/STONES Z-W/COBBLES/BOULDERS X X-SAND & CLAY E S E-CLEAN S-SAND			Surface 20 20 30 30 43	
6. Casing, Liner, Screen													
Dia. (in.)	Material, Weight, Specification			From (ft.)	To (ft.)								
6	STEEL SCH 40 WHEATLAND WELDED			Surface	40.25								
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)								
6	SS 16 SLOT			39	43								
7. Grout or Other Sealing Material													
Method DRIVEN DRY													
Kind of Sealing Material			From (ft.)	To (ft.)	# Sacks Cement								
BENTONITE			Surface	40.25	3 S								
8. Geology													
9. Static Water Level						11. Well Is							
20 ft. below ground surface						24 in. above grade							
10. Pump Test						Developed ? Yes							
Pumping level 40 ft. below surface						Disinfected ? Yes							
Pumping at 12 GP M for 0.5 Hrs.						Capped ? Yes							
Pumping Method ? Airlift													
12. Notified Owner of need to fill & seal ? Yes													
Filled & Sealed Well(s) as needed? No													
N/A													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
EK						6720		10-29-2022					
Drill Rig Operator						Lic or Reg #		Date Signed					
LK						8882		11-02-2022					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		60	Septic or Holding, or POWTS Tank		90

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	10/25/2022	DELAYED WATER SAMPLING

Created On: 12-02-2022

Updated On: 08-11-2023

Review Status: APPROVED