Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZM755

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: VOGEL, WARREN & LINDA	Phone #: (262)993-2613
Mailing Address: 1253 OSTERBERG PKWY	
City: NIAGARA	State: WI — Zip Code: 54151
County: Florence	Co. Permit #:
Notification #: 8927054401	Completed: 10-12-2022
Well Constructor (Business Name): KLEIMAN, ERIK P	Lic. #: 6720
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: KLEIMAN PUMP & WELL DRLG PO BOX 704 IRON MOUNTAIN MI 49801-0704	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location

Town of AURORA	Fire # (if avail.): 1253
Street Address or Road Name and Number: OSTERBERG PKWY	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.7612 °N -88.1547 °W	Method Code: GPS008
SE SW or Govt Lot #:	Section: 17 — Township: 38 N — Range: 19 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	120

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	25
		C		C-CLAY	25	54
G		Q		G-GRAY Q-GRANITE	54	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND SCH 40 STEEL WELDED	Surface	53
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 120 ft. below surface

Pumping at 4.5 GP M for 0.5 Hrs.

Pumping Method ? Airlift

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BENTONITE DRIVEN DRY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	53	4 S

12. Notified Owner of need to fill & seal ? No

N/A

Filled & Sealed Well(s) as needed? No

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
EK	6720	10-18-2022
Drill Rig Operator	Lic or Reg #	Date Signed
LK	8882	10-12-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		100

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	10/12/2022	DELAYED WATER SAMPLING

Created On: 12-02-2022 Updated On: 08-11-2023 Review Status: APPROVED