

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZM757		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner HERMANSON, JEFF						Phone # (920)858-8225		1. Well Location				Fire # (if avail.)			
Mailing Address 1424 N HARRIMAR ST						Town of BLACKWELL						6277			
City APPLETON						State WI		Zip Code 54911				Street Address or Road Name and Number CLEMENS LN			
County Forest		Co. Permit #		Notification # 8919826901		Completed 10-04-2022		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) KLEIMAN, ERIK P				Lic. # 6720		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.5993 °N -88.4287 °W				Method Code GPS008	
Address KLEIMAN PUMP & WELL DRLG PO BOX 704 IRON MOUNTAIN MI 49801-0704				Well Plan Approval #		NE SE		Section 13		Township 36 N		Range 16 E			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2				2. Well Type New Well					
3. Well serves 1 # of HOME				Hicap Well ? No		or Govt Lot #				of previous unique well # constructed in					
Private, potable				Hicap Property ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled					
Heat Exchange ___ # of drillholes				Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		240		No Rotary - Mud Circulation No Yes Rotary - Air Yes No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S Z				S-SAND Z-W/COBBLES/BOULDERS				Surface		25					
Z				Z-CLAY & GRAVEL				25		62.75					
G Q				G-GRAY Q-GRANITE				62.75		100					
G Q				G-GRAY Q-GRANITE				100		240					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL SCH 40 WHEATLAND WELDED				Surface		61.75							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method DRIVEN DRY, CHIPS															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
BENTONITE				Surface		61.75		4 S							
9. Static Water Level															
10 ft. below ground surface															
10. Pump Test															
Pumping level 240 ft. below surface															
Pumping at 48 GP M for 0.5 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? No															
N/A															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
EK				6720		10-04-2022									
Drill Rig Operator				Lic or Reg #		Date Signed									
LK				8882		10-04-2022									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Privy		130

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	10/04/2022	DELAYED WATER SAMPLING

Created On: 12-02-2022

Updated On: 08-11-2023

Review Status: APPROVED